



A Miniratna Cat-1 Company

सन्दूरल कोलफील्ड्स लिमिटेड

(भारत सरकार का एक उपक्रम)

CENTRAL COALFIELDS LIMITED

(Govt. of India Undertaking)

वेबसाइट/Website : <http://www.ccl.gov.in>

Ref. : RE TOPA/E&M/Certification/26-27/2026
A

Date : 25/07/2026

TO WHOM IT MAY CONCERN

This is to certify that electrical connection with installation/wiring of DAV Public School, CCL- Kuju Area, Distt: Ramgarh was done by Central Coalfields Limited with below furnished particulars. The whole process of electrification and electrical installation was designed and done by the concerned electrical employers with subsequent inspection and testing by the undersigned.

The lighting conductor is also installed to arrest thundering and to protect the building.

Particulars of Installation;

1. Service wire(Capacity in Amp.): 16 Sq. mm 4 core Copper Cable
2. MCB(Capacity): Adequate rating at required place
3. Supply Conductors Material: ACSR Conductor- 4 wire Rabbit Conductor
4. Voltage rating : 415 Volt
5. Earthing: G.I. Strip with chemical 50 mm dia Pipe Earth Pit
6. Lighting Conductor- Installed

This school is comprising of two storeys and has installed all the fire prevention and safety requirements for its students.

Seven no. of fire extinguishers and three sand buckets have been fixed in different places of the school building like Science Lab, Computer Lab, Library, School Office, Principal's Chamber & Corridors. The building/ premises is safe from fire with w.e.f. 25.10.2025 to a period of one year.

Principal

**D.A.V. PUBLIC SCHOOL
Topa Colliery, CCL (Kuju Area)
Dist.-Ramgarh-825330 (JH)**

Signature with Seal: _____

Name

: Kunwar Abhigyan

Designation

: Project Engineer (E&M) / Topa

Project

PROJECT ENGINEER (E&M)